City of Minden
P.O. Box 239, 325 N. Colorado
Minden, Nebraska 68959

phone 308.832.1820
fax 308.832.1949
www.MindenNebraska.org

The Christmas City
Minden NEBRASKA

ADOPTING ORDINANCE
ORDINANCE NO. 1269

AN ORDINANCE TO AMEND CHAPTER 86, ARTICLE IV OF THE MUNICIPAL CODE OF MINDEN, KEARNEY COUNTY, NEBRASKA, BY AMENDING SECTION 86-187 AS THE SAME RELATES TO WATER; AND PROVIDING FOR THE PUBLICATION OF THIS ORDINANCE IN PAMPHLET FORM.

PASSED AND APPROVED this 15th day of August, 2022.

/s/ Ted Griess
Ted Griess, Mayor

ATTEST:

/s/ Abbey Jordan
Abbey Jordan, City Clerk

(SEAL)

City of Minden
P.O. Box 239, 325 N. Colorado
Minden, Nebraska 68959

phone 308.832.1820
fax 308.832.1949
www.MindenNebraska.org

The Christmas City
Minden NEBRASKA

ORDINANCE NO. 1269

AN ORDINANCE TO AMEND CHAPTER 86, ARTICLE IV OF THE MUNICIPAL CODE OF MINDEN, KEARNEY COUNTY, NEBRASKA, BY AMENDING SECTION 86-187 AS THE SAME RELATES TO WATER; AND PROVIDING FOR THE PUBLICATION OF THIS ORDINANCE IN PAMPHLET FORM.

BE IT ORDAINED BY THE MAYOR AND CITY COUNCIL OF THE CITY OF MINDEN, KEARNEY COUNTY, NEBRASKA.

Section 1. That Section 86-187, Drilling be amended in the Municipal Code of the City of Minden, Kearney County, Nebraska, the same to read as follows:

Section 86-187. Drilling

(a) Water well construction. No person shall drill any water well within the corporate limits of the city within 300 feet of an established water main which has been placed in service by the city, unless a permit therefor has been issued by a three-fourths vote of the city council. Wells shall be drilled in accordance with the city's current standards for water well construction.

1. Whenever it becomes necessary for a public municipal purpose the City of Minden shall be allowed to drill a water well for potable or non-potable use. The City Council shall approve the drilling of such well, and such well shall be drilled in accordance with the city's current standards for water well construction.

2. Whenever said municipal well is for a public purpose, if necessary, it may be drilled within 300 feet of any established water main.

(b) Distance requirements. In order to protect the municipal potable water supply, the following distances from a well shall be enforced:

Category	Distance	
	Feet	Meters
Nonpotable water well	1,000	300
Sewage lagoon	1,000	300
Absorption or disposal field for waste	500	150
Cesspool	500	150
Dump	500	150
Feedlot or feedlot runoff	500	150

City of Minden
P.O. Box 239, 325 N. Colorado
Minden, Nebraska 68959

phone 308.832.1820
fax 308.832.1949
www.MindenNebraska.org

The Christmas City
Minden NEBRASKA

Corral	500	150
Pit toilet	500	150
Sanitary landfill	500	150
Chemical or petroleum product	500	150
Septic tank	500	150
Sewage treatment plant	500	150
Sewage wet well	500	150
Sanitary sewer connection	100	30
Sanitary sewer manhole	100	30
Sanitary sewer line	50	15
Sanitary sewer line (permanently water tight)	10	3

When surface runoff or underground movement from potential sources of contamination may adversely affect the quality of water from such supplies, the distance separating these potential sources of contamination and the well or spring should be greater than that listed in the above schedule.

(C.O. Ord No. 1269, 8/15/2022)

Section 2. That any other ordinance or section passed and approved prior to the passage, approval and publication or posting of this ordinance and in conflict with its provisions is hereby repealed.

Section 3. This ordinance shall be known as Ordinance No. 12XX and shall be in full force and effect from and after its passage, approval and publication according to law.

Passed and approved this 15th day of August, 2022.

/s/ Ted Griess
Ted Griess, Mayor

ATTEST:

/s/ Abbey Jordan
Abbey Jordan, City Clerk
(SEAL)